



Certificate / Certificat Zertifikat / 合格証

PBM 1111013 C003

exida hereby confirms that the:

IM Series Ball Valve

PBM, Inc.

Irwin, PA - USA

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFD_{AVG} and Architecture Constraints
must be verified for each application**

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer
may use the mark:



Valid until October 1, 2018
Revision 1.2 September 30, 2015



ANSI Accredited Program
PRODUCT CERTIFICATION
#1004



Evaluating Assessor

Certifying Assessor

PBM 1111013 C003

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFD_{AVG} and Architecture Constraints
must be verified for each application**

Systematic Capability:

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*

Failure Rates for Sanitary Ball Valve – 2-way

| Application | λ_{SD} | λ_{SU} | λ_{DD} | λ_{DU} |
|--------------------------|----------------|----------------|----------------|----------------|
| Full Stroke | 0 | 0 | 0 | 453 |
| Tight Shut-Off | 0 | 0 | 0 | 1319 |
| Open on Trip | 0 | 145 | 0 | 308 |
| Full Stroke with PVST** | 0 | 0 | 154 | 299 |
| Tight Shut-Off with PVST | 0 | 0 | 154 | 1165 |
| Open on Trip with PVST | 145 | 0 | 154 | 154 |

Failure Rates for Sanitary Ball Valve – 3-way

| Application | λ_{SD} | λ_{SU} | λ_{DD} | λ_{DU} |
|--------------------------|----------------|----------------|----------------|----------------|
| Full Stroke | 0 | 0 | 0 | 586 |
| Tight Shut-Off | 0 | 0 | 0 | 1207 |
| Open on Trip | 0 | 117 | 0 | 469 |
| Full Stroke with PVST** | 0 | 0 | 250 | 336 |
| Tight Shut-Off with PVST | 0 | 0 | 250 | 957 |
| Open on Trip with PVST | 117 | 0 | 250 | 219 |

* FIT = 1 failure / 10⁹ hours

** PVST= Automated Partial Valve Stroke Test

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{AVG} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: PBM 11/10-013 R005 V1 R2

Safety Manual: FRM011, Rev0 or later

